


# Impacts of PHEV and PHEV+EV Charging on Electric Demand in Illinois in 2030

Prakash Thimmapuram  
Computational Scientist

ARGONNE NATIONAL LABORATORY

# Power System Representation




- 2,500 transmission lines
- 1,900 Buses
- 160 Thermal Units
- 63 Wind Farms
- 40 Solar Farms
- 870 Load Buses

# System Simulation


- Electricity Market Complex Adaptive System (EMCAS) used to simulate the hourly operations of the power system.
- Simulated one week each in the months January, April, July and October representing the four seasons.
- External loads are included as price elastic loads to facilitate export of nuclear and wind generation during low load periods.

# Load Forecast



- The non-vehicle electric load is updated based on the long-term projections of annual and peak load projections for ComEd and Ameren areas by PJM Interconnections and the MISO.
- Applied a load shaping algorithm to bus-level hourly loads from 2007 to scale to 2030 by matching area hourly, annual and peak load profiles.

# Vehicle Load



- Penetration in 2030
  - 10% PHEV of light duty vehicles
  - 10% PHEV + 5% of light duty vehicles
- Charging Scenarios
  - Unconstrained
  - Smart

# Retirements

- Any coal or fuel oil or nuclear powered unit whose age will be 60 years or more by 2030
- Any natural gas powered unit whose age will be 40 years or more by 2030
- Capacity that will be retired by 2030
  - 4032 MW of bituminous and 5730 MW of sub-bituminous
  - 572 MW of fuel oil and 678 MW of natural gas
  - No Nuclear units retired

# Renewable Energy Portfolio Standards

- 25% of electric sales by 2026 should come from renewable resources of which at least 75% from wind and 6% from solar resources.
- 13,100 MW of Wind-turbines by 2030
- 1,620 MW of Solar capacity by 2030
- Solar and Wind Profiles
  - Based on PV Watts
  - Based on Eastern Wind Integration Study

# Uprates and Capacity Expansion


- Assumed uprates that have been filed by Exelon and approved by NRC will be implemented by 2030 (1,115 MW).
- 5,500 MW of thermal capacity is required to maintain a 15% reserve margin.
  - 12 combined cycle plants (400 MW each)
  - 3 gas turbines (230 MW each)
- Minimal changes to transmission lines.




# Capacity Mix and Generation

2030 Base Capacity


Illinois



2030 Base Generation





# Generation by Fuel Type



# Generation with Vehicle Loads

2030 Generation with PHEVs

2030 Generation with PHEVs+EVs



# Conclusions

- Charging upon arrival adds significant load in the late afternoon hours, which partially overlaps with the system load peak hours.
- Smart charging fills the overnight trough in the daily demand profile.
- The smart charging resulted in more dispatching of coal power plants compared to the arrival time charging (69% vs. 27% share of coal generation in the marginal mix for the smart charging and arrival time charging scenarios, respectively).